



Ref. Certif. No.

**SG ITS-37403**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Crystalline Silicon Terrestrial Photovoltaic Module
Name and address of the applicant	Philadelphia Solar Al Qastal Industrial Area 2, Airfreight Road, Amman, Jordan
Name and address of the manufacturer	Philadelphia Solar Al Qastal Industrial Area 2, Airfreight Road, Amman, Jordan
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Philadelphia Solar Al Qastal Industrial Area 2, Airfreight Road, Amman, Jordan
Ratings and principal characteristics	Maximum System voltage 1500V, Application class A, Class II, Maximum over-current protection rating 30A
Trademark (if any)	Philadephia Solar
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	PS-MNG156(HCBF)-xxxW (xxx = 605 to 665, in step of 5) PS-MNG144(HCBF)-xxxW (xxx = 555 to 615, in step of 5) PS-MNG132(HCBF)-xxxW (xxx = 510 to 560, in step of 5) PS-MNG120(HCBF)-xxxW (xxx = 460 to 510, in step of 5) PS-MNG108(HCBF)-xxxW (xxx = 415 to 460, in step of 5)
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 61730-1:2023 IEC 61730-2:2023 IEC 61215-1:2021 IEC 61215-2:2021 IEC 61215-1-1:2021
As shown in the Test Report Ref. No. which forms part of this Certificate	240600252SHA-003, 240600252SHA-004

This CB Test Certificate is issued by the National Certification Body

Intertek Testing Services (Singapore) Pte Ltd  
5, Pereira Road, #06-01  
Asiawide Industrial Building  
Singapore 368025

Date: 21 November 2024



Signature:

Ong Keng Chuan